

**LINCOLN COUNTY HEALTH DEPARTMENT**

302 NORTH ACADEMY STREET, SUITE B • LINCOLNTON, N.C. 28092 • (704) 736-8426

Application Type: EH IMPROVEMENT APPLICATION

Date: 10/18/07

Permit #: 07-90001044 PIN: 3693 -00 -16 -5732 Parcel ID: 32566

Owner: HECHT DEVELOPMENT CO (704) 483-1183

C/O BOB HECHT 38BB NC 16 HWY N DENVER NC 28037

Applicant:

Directions to property: N INGLESIDE FARM RD  
 AUTUMN WOODS, LOT 5 . FROM 16 & 73 W  
 ON HWY 16 TO R ON INGLESIDE RD, NORTH 2  
 MILES TO R.

005

T/S: 10/18/2007 09:25 AM FSTAMEY ---


Residence: Y

Nbr of Bedrooms: 5

Water Supply: PRIVATE

**IMPROVEMENT PERMIT**

- REPAIR (SEPTIC/WELL)
- LOT DENIED
- NEW WELL/REPLACEMENT



AUTHORIZATION TO CONSTRUCT

TYPE OF SYSTEM \_\_\_\_\_

TANK SIZE \_\_\_\_\_ *N/A*

ABSORPTION AREA \_\_\_\_\_

TRENCH WIDTH & LENGTH & DEPTH \_\_\_\_\_

NUMBER OF TRENCHES \_\_\_\_\_

TRENCH SPACING \_\_\_\_\_ OC

GRAVEL DEPTH \_\_\_\_\_

DISTANCE TO WATER SUPPLY 100' FT.

DESIGN FLOW 600 gpd LTAR N/A

CONDITIONS DO NOT INSTALL WHEN WET

\_\_\_\_\_

HEALTH DEPT. REP. [Signature]

DATE: 1-2-11-07

**FINAL COMPLETION**

- OP
- WELL COC
- RC

-New applicants must reapply for an authorization to construct and well permit, if applicable, at the current fee in order to obtain a building permit and have septic system and well installed.

-New applicant must remark all structures and property lines as marking policy states before our office revisits the site to issue the authorization to construct permit.

TANK MANUFACTURER \_\_\_\_\_

TANK SIZE \_\_\_\_\_

ABSORPTION AREA \_\_\_\_\_

TRENCH WIDTH & LENGTH & DEPTH \_\_\_\_\_

NUMBER OF TRENCHES \_\_\_\_\_

GRAVEL DEPTH \_\_\_\_\_

DISTANCE TO WATER SUPPLY \_\_\_\_\_ FT.

INSTALLER \_\_\_\_\_

CONDITIONS \_\_\_\_\_

\_\_\_\_\_

HEALTH DEPT. REP. \_\_\_\_\_

DATE: \_\_\_\_\_

IMPROVEMENT PERMIT: THIS IMPROVEMENT PERMIT IS SUBJECT TO REVOCATION IF SITE PLANS OR THE INTENDED USE ARE CHANGED FROM THOSE SHOWN ON PERMIT. CHANGES FROM THE ABOVE PERMIT REQUIRE HEALTH DEPARTMENT APPROVAL. INSTALLER SHALL BE REQUIRED TO HAVE AN "AUTHORIZATION TO CONSTRUCT" (VALID FOR 60 MONTHS) BEFORE INSTALLING THE ABOVE SYSTEM.

FINAL COMPLETION: FINAL APPROVAL OF THIS SYSTEM SHALL INDICATE THAT THE SYSTEM HAS BEEN INSTALLED IN ACCORDANCE WITH STATE REGULATIONS, BUT IN NO WAY SHOULD BE TAKEN AS A GUARANTEE THAT THE SYSTEM WILL FUNCTION SATISFACTORY FOR ANY GIVEN TIME.