

7

CONDITIONS OF IMPROVEMENT PERMIT / CONSTRUCTION AUTHORIZATION

Permit Number: 6148B

Tax Number: 01523101 PO

- The IMPROVEMENT PERMIT is subject to revocation if site plans or the intended use change. There is to be NO grading, filling, or disturbance of the soil in the area of the septic tank system or repair area.
- CONSTRUCTION AUTHORIZATION must be obtained prior to receiving a Building Permit. The Construction Authorization is NOT transferable. Do not clear, grade, fill or disturb soil prior to obtaining a Construction Authorization.
- Domestic-type wastewater only. No industrial process wastewater may be discharged into the system.

Basement: Yes No Partial Basement

Primary Wastewater System
 Type: I II III IV V VI Conventional Low Pressure Pipe Innovative or Experimental:
 Prefabricated, permeable block panel system Large Diameter Pipe Fill
 Shallow Placed Conventional Other

0.3 Long-term acceptance rate (GPD/ft ²)	480 Max gallons/day wastewater flow	1200 Absorption Area (ft ²)	9 Trench spacing (min. on centers) (ft)
Served by private well: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	1500 Gallon septic tank	400 Total trench length (ft)	30 Maximum trench depth (in) (At least 12" of provisionally suitable soil must remain between trench bottom and unsuitable soil conditions.)
4 Bedrooms in residence	1000 Gallon pump tank	NA Depth of stone (in)	

Any surface water present: NO Type: Minimum separation distance (ft):

Additional conditions:

Repair Area System
 Type: I II III IV V VI Conventional Low Pressure Pipe Innovative or Experimental:
 Prefabricated, permeable block panel system Large Diameter Pipe Fill
 Shallow Placed Conventional Other

1200 Absorption Area (ft ²)	NA Depth of stone (in)	9 Trench spacing (min. on centers) (ft)	24 Maximum trench depth (in)
400 Total trench length (ft)			

The undersigned, an authorized agent of the MECKLENBURG COUNTY HEALTH DEPARTMENT, certifies that the Department has approved the Request for the Job Location contained in this document. The approval is granted in accordance with the provisions of Laws and Rules For Sewage Treatment, and Disposal Systems in effect at the time of issuance of the permit and is subject to the following provisions:

*** No work shall be conducted on the septic tank system until an Installation, Construction, Alteration and/or Repair Approval is granted by this Department.

*** This Improvement permit is transferable.

[Signature]
 DENR Authorized Agent Date 1/18/06

[Signature]
 Owner/Agent/Signature Date 1-19-06

MECKLENBURG COUNTY HEALTH DEPARTMENT
 ENVIRONMENTAL HEALTH DIVISION
 700 N. TRYON ST., SUITE 211
 CHARLOTTE, NC 28202
 PHONE: (704) 336-5103
 FAX: (704) 336-6894

NC DENR
 DIVISION OF ENVIRONMENTAL HEALTH
 ON-SITE WASTEWATER SECTION



JUDITH L. MITC
17869/97.

